


Attestation No. 19.31.204

TELL-Classification

according to the Classification Scheme for Energy Efficiency Labelling of thermostatic radiator valves by EUnited Valves, dated 26.04.2011

Manufacturer	Schlösser Heiztechnik Gruppe Polska ul. Przelecz 27 60-115 Poznan Poland
Manufacturing plant	Schlösser Heiztechnik Gruppe Polska ul. Przelecz 27 60-115 Poznan Poland
Product	Thermostatic radiator valve
Model/Type	head with integral sensor: 600010001 DN 15 angle valve: 601200005
<u>Influence of water temperature</u>	1,1 K
<u>Hysteresis</u>	0,65 K
<u>Response time</u>	21 min
<u>Influence of differential pressure</u>	0,5 K
<u>Energy Efficiency Indicator</u>	0,60
The corresponding type test report according to EN 215 / Date of issue	A 18.SHP.105 / 24.10.2018 (Please use this date when applying for the online registration)

Stuttgart, 05.02.2019


.....
Dipl.-Ing. (BA) Thomas Haase
Deputy Laboratory Manager


.....
Dipl.-Ing. J. Nickel
Test Manager